



EC Type Examination Certificate

This is to certify that:

Mueller Refrigeration, LLC
121 Rogers Street
Hartsville
Tennessee
37074
USA

Holds Certificate Number:

CE 69517

In respect of:

Refrigeration Pressure Relief Valves as listed on page 2.

On the basis of our examination under the requirements of Council Directive 97/23/EC Module B of the Pressure Equipment Directive, as transposed into UK law by the Pressure Equipment Regulations SI 1999 2001.

For and on behalf of BSI,
a Notified Body for the above Directive
(Notified Body Number 0086):



Gary Fenton, Global Assurance Director

First Issued: 28/09/2011

Latest Issue: 14/10/2014

Expiry date: 27/10/2022

EC Type Examination Certificate

No. CE 69517

Additional Information

Limitations of Certificate Validity

PS = 48.3 bar g (700 psi g)

TS = -40°C to 149°C (-40°F to 300°F)

Model Numbers:

A-6900, A-6901, A-6902, A-6903, A-6904, A-6996

N-2929

S-34662, S-35799, S-35824, S-35876, S-35991, S-35996

S-36375, S-36660, S-36661, S-36677, S-36678, S-36782, S-36786, S-36790

S-36801, S-36823, S-36845, S-36868, S-36954, S-36962

S-37268, S-37269, S-37319, S-37325, S-37360.

First Issued: 28/09/2011

Latest Issue: 14/10/2014

Expiry date: 27/10/2022

Page 2 of 2

This certificate remains the property of The British Standards Institution and shall be returned immediately upon request.
To check its validity telephone +44 (0)845 080 9000

Information and contact: BSI, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP. Tel: +44 845 080 9000.
BSI Assurance UK Limited, registered in England under number 7805321, at 389 Chiswick High Road, London, W4 4AL, UK.
A member of the BSI Group of Companies.