

February 07, 2025

Attention: Cecylia Garbacz
TECHNICAL STANDARDS & SAFETY AUTHORITY
345 CARLINGVIEW DRIVE
TORONTO, ON M9W 6N9

The design submission, Tracking Number 2024-07355, Web Portal Number 2024-S5359, originally received on December 06, 2024 was surveyed and closed for registration as follows:

CRN : 0C1241.92 - Exempt

Closed on: February 07, 2025

Reg Type: RENEWAL

Expiry Date: May 24, 2034

Drawing No. : Scope of Registration

Fitting type: Refrigerant Valve

- This file has been closed per client request. An invoice has been sent for services rendered.
- The registration of the fittings tested and certified per UL-207 standard used in refrigeration systems having a prime mover of 125 KW or less is not required per IB23-035.

An invoice covering survey fees will be forwarded from our Revenue Accounts.

If you have any question don't hesitate to contact me by phone at (587) 943-8741 or fax (403) 291-4545 or e-mail Zhangl@absa.ca.

Sincerely,



ZHANG, LILI, P. Eng.
DOP Cert. No. D00010626