



345 Carlingview Drive
Toronto, Ontario M9W 6N9
Tel.: 416.734.3300
Fax: 416.231.1626
Toll Free: 1.877.682.8772
www.tssa.org

August 31, 2026

MUELLER REFRIGERATION LLC
121 ROGERS ST
HARTSVILLE TN 37074

Workorder Type: Registration - Fitting(Conventional)
Workorder No: 15122238
Your Reference No.: 0G0314.9C
Registered to: MUELLER REFRIGERATION LLC

Dear Pernell Copass,

Technical Standards and Safety Authority (TSSA) is pleased to inform you that your submission has been reviewed and registered as follows:

CRN : 0G0314.95R7

Main Design No.: Declaration# OG0314.95C & Attached Scope of Registration

Expiry Date: Jul 10, 2036

Registration Note:

1. Renewal of CRN 0G0314.95R6
2. Scope revised to remove models A15501, A15508, A15509, and B34067

Please be advised that a valid quality control system must be maintained for the fitting registration to remain valid until the expiry date.

The stamped copy of the approved registration and the invoice are mailed separately (There will be no hard copies for electronic submissions). Should you have any questions or require further assistance, please contact a Customer Service Advisor at 1.877.682.TSSA (8772) or e-mail customerservices@tssa.org. We will be happy to assist you. When contacting TSSA regarding this file, please refer to the Service Request number provided above.

Yours truly,

Junho Hong P.Eng. PMP.
Engineer, BPV
Tel. : +1 416-734-6233
Email : JHong@tssa.org



Technical Standards & Safety Authority
345 Carlingview Drive
Toronto, Ontario
M9W 6N9
www.tssa.org

(Show facsimile of logo or trademark, as it will appear on the fitting as evidence of certification)



DECLARATION OF CONFORMITY REGISTRATION OF FITTINGS



The stamp size has been optimized for 11x17 documents. This Document has been digitally signed and approved.

FOR TSSA OFFICE USE ONLY

Technical Standards and Safety Authority
Boilers and Pressure Vessels Safety Program

REGISTERED

C.R.N.: 0G0314.95R7

Signed: *[Signature]*

Date: August 31, 2026

Expiry Date: Jul 10, 2036

Declaration No.: (document no. as issued by the manufacturer)

0G0314.95C

Revision:

Manufacturer (Name and Address)

Mueller Refrigeration, LLC, 121 Rogers Street, Hartsville, TN 37074, United States

Registration Note:

1. Renewal of CRN 0G0314.95R6
2. Scope revised to remove models A15501, A15508, A15509, and B34067

***Table 1 Scope of Fitting Designs**

Item No.	Type / Model	Product Description	Material of Construction	MDMT	Rated Pressure		References: Catalog (pages) or Drawing(s)
					At Ambient Temperature	At Maximum Temperature	
1	Please see	attached	scope			at	
2						at	
3						at	
4						at	
5						at	

****Table 2 Codes, Standards, Guidelines, and Other Applicable Documents**

Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision	Item No.	Title of Code(s), Standard(s), Guideline(s), or Other Applicable Document(s)	Edition / Revision
1	ASME Section VIII, Division 1	2025	4		
2	ASME Section XIII	2025	5		
3			6		

*****Table 3 Quality Program Verification and Manufacturing Sites**

Item No.	Location(s) Plant Name and Address / Site(s)	Quality Program Certificate Number	Expiry Date	Verifying Organization
1	Mueller Refrigeration, LLC, 121 Rogers Street, Hartsville, TN 37074	FM 769345	11/27/2026	BSI
2				
3				

A copy of the Quality Certificate from each manufacturing site must be included.

Remarks

(other relevant information)

As an official of the manufacturer with authority, and having responsibility for the conformity and regulatory compliance of the fittings, I hereby declare that the information and statements made in this declaration of conformity are true and accurate.

I declare, under our sole responsibility, that the design, construction, certification, and marking of the fitting(s) listed in Table 1*, are subject to a conformity assessment process and quality program that has been verified, as described in Table 3***.

I certify that the fittings (s) listed in Table 1* conform to: the provisions of the acts and regulations of the provinces and territories where the fitting(s) are registered; CSA B51; and the codes, standards, guidelines, or other applicable documents listed in Table 2**.

I further declare that there is a process in place for the retention of this declaration of conformity for not less than 10 years from the issuance of the Canadian Registration Number (CRN).

Signed for and on behalf of Mueller Refrigeration, LLC in the Hartsville of Tennessee
(Manufacturer) (City) (State / Province, Country)

Pernell Copass Pernell Copass 7/13/2026
(Name, please print) (Function or Title) (Signature of Declarer) (Date)

Digitally signed by Pernell Copass
Date: 2026.07.13 09:28:22 -05'00'

Scope of Registration - Mueller Pressure Relief Valves

Type/ Model	Body Part No.	Description	Size	Pressure Range	Min Temp	Max Temp	Material	Design Code
A 15502	A 06901	Pressure Relief Valve	3/8" NPTF X 3/8" Flare	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 15503	A 06901	Pressure Relief Valve	3/8" NPTF X 1/2" Flare	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 15504	A 06902	Pressure Relief Valve	1/2" NPTF X 5/8" Flare	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 15506	A 06903	Pressure Relief Valve	3/4" NPTF X 3/4" NPTF	150 - 450	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 15512	A 06901	Pressure Relief Valve	3/8" NPTF X 3/8" Flare	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 15513	A 06901	Pressure Relief Valve	3/8" NPTF X 1/2" Flare	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 15514	A 06902	Pressure Relief Valve	1/2" NPTF X 5/8" Flare	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 17430	A 06901	Pressure Relief Valve	3/8" NPTF	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 17834	S 35991	Pressure Relief Valve	1-1/4" NPTF X 1-1/4" NPTF	150 - 450	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 17840	A 06904	Pressure Relief Valve	1" NPTF X 1" NPTF	150 - 450	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 17970	S 36375	Pressure Relief Valve	1" NPTF	150 - 450	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 18356	S 36660	Pressure Relief Valve	1/2" NPTF X 1/2" NPTF	150 - 450	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 18357	S 36660	Pressure Relief Valve	1/2" NPTF X 3/4" NPTF	150 - 450	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 18358	S 36661	Pressure Relief Valve	3/4" NPTF X 3/4" NPTF	150 - 450	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 18387	S 36678	Pressure Relief Valve	1" NPTF X 1" NPTF	150 - 450	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 18422	S 36782	Pressure Relief Valve	3/4" NPTF X 3/4" NPTF	600 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 18424	S 36790	Pressure Relief Valve	1" NPTF X 1" NPTF	150 - 450	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 18425	S 36786	Pressure Relief Valve	1-1/4" NPTF X 1-1/4" NPTF	150 - 450	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 18443	S 36823	Pressure Relief Valve	1" NPTF	150 - 450	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 18444	S 36845	Pressure Relief Valve	1" NPTF X 1- 1/4" NPTF	150 - 450	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 18473	S 36868	Pressure Relief Valve	1-1/2" NPTF	150 - 450	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 18540	S 36962	Pressure Relief Valve	7/8-14 UNF- 2A X 3/4" NPTF	150 - 450	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII

A 18735	S 37325	Pressure Relief Valve	3/4" NPTF X 1" NPTF	150 - 450	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 18736	S 37319	Pressure Relief Valve	3/8" NPTF X 3/4" NPTF	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 18737	S 37319	Pressure Relief Valve	3/8" NPTF X 5/8" Flare	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 18762	A 06902	Pressure Relief Valve	1/2" NPTF X 3/4" NPTF	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 18774	S 37360	Pressure Relief Valve	1/8" NPTF	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 18783	S 37319	Pressure Relief Valve	3/8" NPTF X 1/2" Flare	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 18784	S 37319	Pressure Relief Valve	3/8" NPTF X 1/2 Fl Angle	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 19105	S 37706	Pressure Relief Valve	1-1/16-12 UN-2A X 5/8" Flare	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
A 19108	A 06901B	Pressure Relief Valve	9/16-18 UNF-2A	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
B 33746	S 34662	Pressure Relief Valve	1/4" NPTF X 3/8" Flare	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
B 33752	S 34662	Pressure Relief Valve	1/4" NPTF x 3/8" Flare	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
B 33753	S 34662	Pressure Relief Valve	1/4" NPTF X 1/2" Flare	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
B 33754	S 34662	Pressure Relief Valve	1/4" NPTF X 1/2" Flare	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
B 33755	S 34662	Pressure Relief Valve	1/4" NPTF	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
B 34425	S 35799	Pressure Relief Valve	3/4" NPTF	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
B 34444	S 35824	Pressure Relief Valve	7/8-14 UNF X 3/4" NPTF	150 - 450	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
B 34519	S 35876	Pressure Relief Valve	1-5/16-12 UNF X 1" NPTF	150 - 450	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
B 34580	S 35996	Pressure Relief Valve	1-5/8-12 UN X 1-1/4" NPTF	150 - 450	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII
B 35413	S 36677	Pressure Relief Valve	7/8-14 UNF X 5/8" Flare	150 - 700	- 40°F/ - 40°C	+300°F/ +169°C	ASME SB-16, UNS C36000	ASME Sec VIII, Div 1; ASME Sec XIII

THIS IS PART OF CRN
0G0314.95R7
 Technical Standards and Safety Authority
 Boilers and Pressure Vessels Safety
 Program

NB18 Report

THIS IS PART OF CRN
0G0314.95R7
Technical Standards and Safety Authority
Boilers and Pressure Vessels Safety
Program

Friday, May 22, 2026

Mueller Refrigeration, LLC (MBC)

Nameplate Abbreviation: Mueller

Hartsville, TN 37074United States

Design Name:		A15502, A15503, A15512, A15513, A17430, A18774, A18933, A18934, A-19108, B33746, B33752, B33753, B33754, B33755 & B34425, B35616		NBCert #	41016
Manufacturer/Assembler		Designators		Expiration Date	
Manufacturer		UV		02/13/2029	
Design Type					
[Safety Relief Valve] A15502, A15503, A15512, A15513, A17430, A18774, A18933, A18934, A-19108, B33746, B33752, B33753, B33754, B33755 & B34425, B35616					
Capacity Tests: Sec. UV at unknown lab on January 3, 1956					
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method					
Certified Value: 0.438 SCFM/PSIA					
Media - Test: Air/Gas; Certified: Gas					
Set Pressure Definition: Bubble					
Blowdown Characteristics: Fixed					
Flow Area Configuration: Nozzle/Full Lift					
Designed by: Mueller Refrigeration, LLC {MBC}					

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.125-0.375 NPS					150-700 psi	Air	UV
	3/8, 1/2 NPS	0.0284 in²	0.19 in		150-700 psi	Air	UV

Design Name: A15504, A15514, A15515, B35413, A18736, A18737 A18762,A18783, A18784, NBCert # 41027 A18935, A19105, A19099					
Manufacturer/Assembler		Designators		Expiration Date	
Manufacturer		UV		05/03/2027	
Design Type					
[Safety Relief Valve] A15504, A15514, A15515, B35413, A18736, A18737 A18762,A18783, A18784, A18935, A19105, A19099					
Capacity Tests: Sec. UV at unknown lab on January 3, 1956					
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method					
Certified Value: 0.965 SCFM/PSIA					
Media - Test: Air/Gas; Certified: Gas					
Set Pressure Definition: Bubble					
Blowdown Characteristics: Fixed					
Designed by: Mueller Refrigeration, LLC {MBC}					

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.375-0.875 NPS	1/2, 5/8, 3/4 NPS	0.0616 in²	0.28 in		150-700 psi	Air	UV

Design Name: A-15506 & B-34444			NBCert # 41049		
Manufacturer/Assembler		Designators		Expiration Date	
Manufacturer		UV		07/31/2031	
Design Type					
[Safety Relief Valve] A-15506 & B-34444					
Capacity Tests: Sec. UV at unknown lab on May 22, 1956					
Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method					
Certified Value: 0.124 lb/min/psia					
Media - Test: Air/Gas; Certified: Gas					
Set Pressure Definition: Bubble					
Blowdown Characteristics: Fixed					
Designed by: Mueller Refrigeration, LLC {MBC}					

THIS IS PART OF CRN

0G0314.95R7

Technical Standards and Safety Authority

Boilers and Pressure Vessels Safety Program

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-0.875 NPS		0.1134 in²	0.38 in		150-450 psi	Air	UV
Design Name: A-17834, B-34580, A-18387, A-18473 NBCert # 41061							
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		07/31/2031		
Design Type							
[Safety Relief Valve] A-17834, B-34580, A-18387, A-18473 Capacity Tests: Sec. UV at National Board Testing Lab on October 29, 1999 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 4.400 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Designed by: Mueller Refrigeration, LLC {MBC}							

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
1-1.625 NPS	1, 1.25 NPS	0.4185 in ²	0.73 in	0.183 in	150-450 psi	Air	UV

THIS IS PART OF CRN
 0G0314.95R7
 Technical Standards and Safety Authority
 Boilers and Pressure Vessels Safety
 Program

Design Name: A-17840, A-18735, & B-34519				NBCert # 41050	
Manufacturer/Assembler		Designators		Expiration Date	
Manufacturer		UV		12/17/2031	

Design Type [Safety Relief Valve] A-17840, A-18735, & B-34519 Capacity Tests: Sec. UV at National Board Testing Lab on July 8, 1999 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.690 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Designed by: Mueller Refrigeration, LLC (MBC)					
--	--	--	--	--	--

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75-1.625 NPS	1 NPS	0.196 in ²	0.5 in		150-450 psi	Air	UV

Design Name: A-17970, A-18443				NBCert # 41072	
Manufacturer/Assembler		Designators		Expiration Date	
Manufacturer		UV		05/03/2027	

THIS IS PART OF CRN
 0G0314.95R7
 Technical Standards and Safety Authority
 Boilers and Pressure Vessels Safety Program

Design Type							
[Safety Relief Valve] A-17970, A-18443 Capacity Tests: Sec. UV at National Board Testing Lab on October 28, 2002 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1,390 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mueller Refrigeration, LLC (MBC)							
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
	1 NPS	0.093 in²	0.375 in		150-450 psi	Air	UV
Design Name: A-18356, A-18357, A-18358, A-18540 NBCert # 41083							
Manufacturer/Assembler			Designators		Expiration Date		
Manufacturer			UV		03/21/2030		
Design Type							
[Safety Relief Valve] A-18356, A-18357, A-18358, A-18540 Capacity Tests: Sec. UV at National Board Testing Lab on August 7, 2007 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1,870 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mueller Refrigeration, LLC (MBC)							

THIS IS PART OF CRN
 OG0314.95R7
 Technical Standards and Safety Authority
 Boilers and Pressure Vessels Safety
 Program

Design Name: A-18422		NBCert # 41106	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	07/31/2031

Design Type	
[Safety Relief Valve] A-18422 Capacity Tests: Sec. UV at National Board Testing Lab on March 16, 2009 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 1.730 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mueller Refrigeration, LLC {MBC}	

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Designator
0.75 NPS	.75 NPS	0.1134 in²	0.38 in		600-700 psi	Air	UV

Design Name: A-18424 (Teflon seat)		NBCert # 41128	
Manufacturer/Assembler		Designators	Expiration Date
Manufacturer		UV	12/17/2031

THIS IS PART OF CRN
 0G0314.95R7
 Technical Standards and Safety Authority
 Boilers and Pressure Vessels Safety
 Program

Design Type						
[Safety Relief Valve] A-18424 (Teflon seat) Capacity Tests: Sec. UV at National Board Testing Lab on January 20, 2009 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 2.906 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mueller Refrigeration, LLC {MBC}						
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media Designator
1 NPS	1 NPS	0.196 in²	0.5 in		150-450 psi	Air UV
Design Name: A-18425, A-18444 (Teflon seat) NBCert # 41117						
Manufacturer/Assembler			Designators		Expiration Date	
Manufacturer			UV		12/17/2031	
Design Type						
[Safety Relief Valve] A-18425, A-18444 (Teflon seat) Capacity Tests: Sec. UV at National Board Testing Lab on October 16, 2008 Method of Establishing Relieving Capacity: Flow Capacity, 4-Device Method Certified Value: 4.330 SCFM/PSIA Media - Test: Air/Gas; Certified: Gas Set Pressure Definition: Bubble Blowdown Characteristics: Fixed Flow Area Configuration: Nozzle/Full Lift Designed by: Mueller Refrigeration, LLC {MBC}						
Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media Designator
1-1.25 NPS	1.25 NPS	0.4185 in²	0.73 in		150-450 psi	Air UV

THIS IS PART OF CRN
OG0314.95R7
Technical Standards and Safety Authority
Boilers and Pressure Vessels Safety
Program

**THE NATIONAL BOARD
OF
BOILER & PRESSURE VESSEL INSPECTORS**

Certificate of Authorization



This is to certify that

**Mueller Refrigeration, LLC
121 Rogers Street
Hartsville, Tennessee 37074
United States**

Acceptable Abbreviation: Mueller

is authorized to use the "NB" mark in accordance with the provisions of NB-501, National Board Certification of Pressure Relief Devices.

The scope of Authorization is limited to the National Board Certified devices which have been manufactured, assembled, and marked in accordance with the construction codes applicable to the following designators:

UV



Issue Date:

March 20, 2026

Expiration Date:

April 20, 2029

Executive Director

A handwritten signature in black ink, appearing to read 'John Doe', is written over a horizontal line.



The American Society of Mechanical Engineers

CERTIFICATE OF AUTHORIZATION

The named company is authorized by The American Society of Mechanical Engineers (ASME) for the scope of activity shown below in accordance with the applicable rules of the ASME Boiler and Pressure Vessel Code. The use of the ASME Single Certification Mark and the authority granted by this Certificate of Authorization are subject to the provisions of the agreement set forth in the application. Any construction stamped with the ASME Single Certification Mark shall have been built strictly in accordance with the provisions of the ASME Boiler and Pressure Vessel Code.

COMPANY:

Mueller Refrigeration, LLC
121 Rogers Street
Hartsville, Tennessee 37074
United States

SCOPE:

Manufacture of pressure vessel pressure relief valves at the above location only
(This authorization does not cover welding, brazing or fusing)

AUTHORIZED: **April 20, 2026**

EXPIRES: **April 20, 2029**

CERTIFICATE NUMBER: **16564**

Gary L. Scribner

Board Chair,
Conformity Assessment



Matthew Vanguey

Senior Director,
Engineering Operations

Certificate of Registration

QUALITY MANAGEMENT SYSTEM - ISO 9001:2015

This is to certify that:

Mueller Refrigeration, LLC
121 Rogers Street
Hartsville
Tennessee
37074
USA

Holds Certificate No:

FM 769345

and operates a Quality Management System which complies with the requirements of ISO 9001:2015 for the following scope:

The design, development and manufacture of valves, driers, flare fittings and flanges for HVAC & Refrigeration. The fabrication and brazing of ferrous and non-ferrous metals.

This certificate is traceable to this company's original registration certificate number 10001760 QM15 dated July 23, 1999, issued by DQS.

For and on behalf of BSI:


Carlos Pitanga, Managing Director Assurance, Americas

Original Registration Date: 1999-07-23

Latest Revision Date: 2023-09-13

Effective Date: 2023-11-28

Expiry Date: 2026-11-27

Page: 1 of 1



...making excellence a habit.™